



DESIGN NOTES:

- (1) COMPLETE SYSTEM TO BE HYDRO TESTED TO 125 PSI PRIOR TO SHIPPING.
- (2) STEEL FRAME AND COMPONENTS TO RECEIVE TWO COATS OF GRAY MACHINE ENAMEL.
- (3) ALL WELDED WATER PIPING TO BE WELDED IN ACCORDANCE TO ASME B31.9
- (4) COMPLETE PACKAGE SYSTEM TO BE UL LISTED.

☉ = DENOTES CONTRACTOR POINT OF CONNECTION

REV	DESCRIPTION	BY	DATE	APPROXIMATE SHIPPING WEIGHT: - LBS.	APPROXIMATE OPERATING WEIGHT: - LBS.
-	-	-	-	-	-

UL LISTED

PACKAGED PUMPING SYSTEMS & HEAT TRANSFER SYSTEMS

THIS DRAWING AND THE INFORMATION OF DESIGN THEREON IS THE PROPERTY OF FLOWTHERM SYSTEMS, A DIVISION OF CALIFORNIA HYDRONICS CORP. COPIES ARE ISSUED IN STRICT CONFIDENCE AND SHALL NOT BE REPRODUCED OR COPIED, OR USED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF CALIFORNIA HYDRONICS CORP.

JOB NAME:	CONTRACTOR:	DRWN.	DATE	CKD.	APPROVED
-	-	-	-	-	-
TOLERANCES UNLESS OTHERWISE SPECIFIED			DEC.	ANGLE	SCALE
.500"			1/2"	5"	D