





HYDRONIC HEATING PACKAGE SCHEDULE

SYMBOL	MANUFACTURER	GAS				CAPACITY, WATER				ELECTRICAL	
		MODEL	MBTU/HR INPUT (MAX/MIN)	MBTU/HR OUTPUT (MAX/MIN)	EFT	GPM	TDH	HWS	HWR		VOLTS/PH
IHM	FLOWTHERM SYSTEMS	CSROFT	800/85	585/79	97.5K	38	65'	160°F	130°F	480/60/3	4.6

PIPE SUPPORTS TO BE INSTALLED AS REQUIRED, SOME NOT SHOWN FOR CLARITY.

SELF VENTS AND CONDENSATE TRAPS AS REQUIRED TO MEET OR EXCEED ALL APPLICABLE CODES AND ANY SEISMIC REQUIREMENT.

ALL BOILERS AND WORKING TO BE COMPLETED WITH LOCAL PERMITS AND ANY SEISMIC REQUIREMENT.



- DESIGN NOTES:**
- (1) COMPLETE SYSTEM TO BE HYDRO TESTED TO 125 PSI PRIOR TO SHIPPING.
 - (2) STEEL FRAME AND COMPONENTS TO RECEIVE TWO COATS OF GRAY MACHINE ENAMEL.
 - (3) ALL WELDED WATER PIPING TO BE WELDED IN ACCORDANCE TO ASME B31.9
 - (4) COMPLETE PACKAGE SYSTEM TO BE UL LISTED.

☐ = DENOTES CONTRACTOR POINT OF CONNECTION

UL LISTED

PACKAGED PUMPING SYSTEMS
&
HEAT TRANSFER SYSTEMS

APPROXIMATE SHIPPING WEIGHT: 2,320 LBS.
APPROXIMATE OPERATING WEIGHT: 2,875 LBS.

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FLOWTHERM SYSTEMS, A DIVISION OF FLOWTHERM CORPORATION. IT IS TO BE USED IN STRICT COMPLIANCE AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, WITHOUT THE WRITTEN PERMISSION OF FLOWTHERM SYSTEMS, A DIVISION OF FLOWTHERM CORPORATION.

JOB NAME: _____
CONTRACTOR: _____

REVISIONS:

NO.	DATE	BY	CHKD.	APPROVED
1	08/08/17			

TOLERANCES UNLESS OTHERWISE SPECIFIED:
FRACTIONAL ANGLES SIZE 1/2" - 1/2"
DECIMAL ANGLES SIZE 1/2" - 1/2"

FlowTHERM Systems

DRAWING TITLE: HYDRONIC HEATING MODULE

DRAWING NO.: IHM-ES001

FAB NO.: _____

REV: _____