



-GPM		-PSI		-PSI		-PSI				
TOTAL FLOW		TOTAL DISCHARGE PRESSURE		TOTAL SYSTEM CAPACITY		AVAILABLE PRESSURE				
ITEM	TAG	MANUFACTURER	SERIES	MODEL	GPM	TDH	HP	RPM	VOLTS/HZ/PH	ENCLOSURE
3	P-2	GOULDS	NPE	1.25 X 1.5-6	—	—	3	3500	460 / 60 / 3	TEFC P.E.
2	P-1	GOULDS	NPE	1.25 X 1.5-6	—	—	3	3500	460 / 60 / 3	TEFC P.E.

PUMP SCHEDULE

RELIEF VALVES AND EQUIPMENT DRAINS TO BE PIPED TO DRAIN OR VENT TO ATMOSPHERE PER CODE REQUIREMENT.

ALL BOLTING AND ANCHORAGE TO BE IN COMPLIANCE WITH LOCAL CODES AND ANY SEISMIC REQUIREMENTS.

GENERAL NOTES:  
 (1) SINGLE POINT POWER CONNECTION AT CONTROL PANEL.  
 (2) HYDRO PRESSURE CHECK AT 125 PSI.  
 (3) ASSEMBLED SYSTEM TO BE PAINTED WITH INDUSTRIAL MACHINE ENAMEL PRIOR TO SHIPMENT.

— = DENOTES CONTRACTOR POINT OF CONNECTION

**UL LISTED**  
 PACKAGED PUMPING SYSTEMS  
 & HEAT TRANSFER SYSTEMS

APPROXIMATE SHIPPING WEIGHT: 624 LBS.  
 APPROXIMATE OPERATING WEIGHT: 665 LBS.

THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF FLOWTHERM SYSTEMS, A DIVISION OF CHC. COPIES ARE BEING MADE FOR YOUR INFORMATION AND NOT TO BE USED FOR MANUFACTURING OR SALE OF THE PRODUCT WITHOUT PRIOR WRITTEN PERMISSION OF CHC.

PROJECT NAME:  
 CUSTOMER:

DRAWN BY DATE: 12/16/14  
 CHECKED BY APPROVED BY  
 TOLERANCES UNLESS OTHERWISE SPECIFIED  
 DEC. .500" FRACTIONAL ANGLE 1/2" SCALE 1" = 1'-0"

**Flowtherm systems**  
 HAYWARD, CALIFORNIA

DRAWING TITLE: VARIABLE SPEED DUPLEX PRESSURE BOOSTER  
 FAB No. DRAWING No. REV A