



RELIEF VALVES AND EQUIPMENT DRAINS TO BE PIPED TO DRAIN OR TO THE STREET PER CODE REQUIREMENT.

ALL BOLTING AND ANCHORAGE TO BE IN COMPLIANCE WITH LOCAL CODES AND ANY SEISMIC REQUIREMENTS.

TOTAL FLOW		PSI		TOTAL DISCHARGE PRESSURE		AVAILABLE PRESSURE				
GPM	PSI	PSI	PSI	PSI	PSI	PSI	PSI			
3	P-2	GOULDS	3656	1 1/2 X 2-6	-	-	5	3500	460 / 60 / 3	TEFC P.E.
2	P-1	GOULDS	3656	1 1/2 X 2-6	-	-	5	3500	460 / 60 / 3	TEFC P.E.
ITEM	TAG	MANUFACTURER	SERIES	MODEL	GPM	TDH	HP	RPM	VOLTS/Hz/PH	ENCLOSURE

PUMP SCHEDULE

UL LISTED
PACKAGED PUMPING SYSTEMS & HEAT TRANSFER SYSTEMS

APPROXIMATE SHIPPING WEIGHT: 876 LBS.
APPROXIMATE OPERATING WEIGHT: 918 LBS.

GENERAL NOTES:
(1) SINGLE POINT POWER CONNECTION AT CONTROL PANEL.
(2) HYDRO PRESSURE CHECK AT 125 PSI.
(3) ASSEMBLED SYSTEM TO BE PAINTED WITH INDUSTRIAL MACHINE ENAMEL PRIOR TO SHIPMENT.

PROJECT NAME:
CUSTOMER:
DRAWN BY DATE: 12/17/14
CHECKED BY APPROVED BY:
TOLERANCES UNLESS OTHERWISE SPECIFIED
DEC. .500" FRACTIONAL ANGLE 5" SCALE 1" = 1'-0"

DRAWING TITLE: VARIABLE SPEED DUPLEX PRESSURE BOOSTER
DRAWING No. FEV2-7
REV A

FLOWTHERM systems
HAYWARD, CALIFORNIA