




RELIEF VALVES AND ANCHORAGE EQUIPMENT DRAINS TO BE IN COMPLIANCE WITH LOCAL CODES AND ANY SEISMIC REQUIREMENTS.

RELIEF VALVES AND EQUIPMENT DRAINS TO BE PIPED TO DRAIN OR VENT BY CONTRACTOR PER CODE REQUIREMENT.



CONSTRUCTION NOTES:
 1. SUCTION AND DISCHARGE HEADERS ARE GROOVED ON BOTH ENDS.
 2. END CAPS CAN BE PLACED ON EITHER END OF HEADERS.
 3. SYSTEM DESIGNED FOR INDOOR INSTALLATION.



-GPM		-PSI		TOTAL SYSTEM CAPACITY											
TOTAL FLOW	TOTAL DISCHARGE PRESSURE	TOTAL DISCHARGE PRESSURE	AVAILABLE PRESSURE												
4	P-3	GOULDS	ESV	22SVG-1	-	-	3	3500	H60	/	60	/	3	TEFC	P.E.
3	P-2	GOULDS	ESV	22SVG-1	-	-	3	3500	H60	/	60	/	3	TEFC	P.E.
2	P-1	GOULDS	ESV	22SVG-1	-	-	3	3500	H60	/	60	/	3	TEFC	P.E.
ITEM	TAG	MANUFACTURER	SERIES	MODEL	TDH	HP	RPM	VOLTS/AHZ/PH	ENCLOSURE	PUMP SCHEDULE					
10	-	-	-	-	-	-	-	-	-						
9	-	-	-	-	-	-	-	-	-						
8	-	-	-	-	-	-	-	-	-						
7	-	-	-	-	-	-	-	-	-						
6	6	-	-	-	-	-	-	-	-	BALL VALVE - 2"					
5	3	-	-	-	-	-	-	-	-	VAL-MATIC WAFER CHECK VALVE - 2"					
4	1	P-3	GOULDS	ESV	22SVG-1	-	-	-	-	GOULDS ESV MULTI-STAGE PUMP MODEL 22SVG-1					
3	1	P-2	GOULDS	ESV	22SVG-1	-	-	-	-	GOULDS ESV MULTI-STAGE PUMP MODEL 22SVG-1					
2	1	P-1	GOULDS	ESV	22SVG-1	-	-	-	-	GOULDS ESV MULTI-STAGE PUMP MODEL 22SVG-1					
1	1	-	-	-	-	-	-	-	-	AQUALOGIC XL CONTROL PANEL					
ITEM	QTY	TAG	DESCRIPTION												

GENERAL NOTES:
 (1) SINGLE POINT POWER CONNECTION AT CONTROL PANEL.
 (2) HYDRO PRESSURE CHECK AT 125 PSI.
 (3) ASSEMBLED SYSTEM TO BE PAINTED WITH INDUSTRIAL MACHINE ENAMEL PRIOR TO SHIPMENT.

UL LISTED
 PACKAGED PUMPING SYSTEMS & HEAT TRANSFER SYSTEMS

APPROXIMATE SHIPPING WEIGHT: 980 LBS.
 APPROXIMATE OPERATING WEIGHT: 1,062 LBS.

PROJECT NAME: _____
CUSTOMER: _____
DRAWN BY DATE: 04/04/18
ACD
CHECKED BY APPROVED BY: _____
TOLERANCES UNLESS OTHERWISE SPECIFIED:
 DEC. .500" FRACTION 1/2" ANGLE 5" SCALE 1" = 1'-0"

EQUIPMENT SCHEDULE

FLOWTECH systems
 HAYWARD, CALIFORNIA

DRAWING TITLE: FMV3.1-SLH-XL - VARIABLE SPEED TRIPLEX PRESSURE BOOSTER
DRAWING NO.: FMV3.1-SLH-XL
REV: 1